Hot tub log

Hot tubs used by paying guests fall under HSE guidance HSG282. Typical ranges: free chlorine 3 to 5 mg/l or bromine 4 to 6 mg/l, pH 7.0 to 7.6, temperature no higher than 40°C. Follow the ranges in your own management plan.

Property

Tub make, model and capacity

Person responsible

Trained by / course and date

Water checks (changeovers, visits and checks in use)

Date	Time	pH	Disinfectant (mg/l)	Temp (°C)	Clarity OK?	Action taken	Initials

Date	Time	pH	Disinfectant (mg/l)	Temp (°C)	Clarity OK?	Action taken	Initials

Water changes and cleaning

Date	Drained and cleaned	Filters cleaned or replaced	Refilled and dosed	By

Lab samples

Date	Type (monthly / legionella)	Lab	Result	Action	By